


Product Certification Schedule

Schedule No: 226/001/001
Licensee: TECNIKABEL S.P.A, 243 VIA BRANDIZZO, 10088 VOLPIANO (TO), ITALY
Factory: TECNIKABEL S.P.A, VIA RIVERA 100, 10040 ALMESE (TO), ITALY
Specification: BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant, screened, fixed installations cables having low emission of smoke and corrosive gases when affected by fire. Part 1 : Multicore cables
Type of Cable: Table 2 Dimensions of 2-core, 3-core and 4-core cables
Range of Approval: 1.5sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive. ENHANCED 120. Additionally tested to BS 6387 Categories C, W & Z. Sheath - LTS3. Insulation - EI5
Origin Thread: Not Applicable
Origin Mark: TECNIKABEL ELECTRIC CABLE

	<p>PERMISSIBLE MARKS</p> <p>BASEC</p> <p>Please refer to the BASEC Product Certification Requirements</p>	<p>YELLOW ACETATE THREAD</p>
---	---	---

Expiry Date: 02/07/2021

Signed for and on behalf of the British Approvals Service for Cables

 _____ Date 03/07/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

